

### **GENERAL DESCRIPTION**

The isolated doubler/converter DAT 4631 A is able to measure and linearise the standard thermocouples with internal or external cold junction compensation. In function of programming, the measured values are converted in a current or voltage signal. The device guarantees high accuracy and performances stability both versus time and temperature.

The programming is made by the dip-switch located in the window on the side of the enclosure. By means of dip-switches it is possible to select the input type and range and the output type without recalibrate the device.

Moreover, by Personal Computer the user can program all of the device's parameters for his own necessity; the configuration by PC allows to program the two outputs with two independent settings. For Thermocouple sensors it is possible to set the Cold Junction Compensation (CJC) as internal or external.

Moreover it is available the option of alarm for signal interruption (burn-out) that allows to set the output value as high or low out of scale .

The 1500 Vac galvanic isolation on all ways (input, outputs and power supply) eliminates the effects of all ground loops eventually existing and allows the use of the converter in heavy environmental conditions found in industrial applications.

The DAT 4631 A is in compliance with the Directive 2004/108/EC on the Electromagnetic Compatibility.

It is housed in a plastic enclosure of 12.5 mm thickness suitable for DIN rail mounting in compliance with EN-50022 and EN-50035 standards.

### **USER INSTRUCTIONS**

The converter must be powered by a direct voltage applied to the terminals Q and R.

The analog channel measures the value from the sensor connected to the terminals the I, L and G and transmits the output measures on the terminals N and M (OUT A) and the terminals P and O (OUT B).


The input and output connections must be made as shown in the section "Connections".

It is possible to configure the converter on field by dip-switch or Personal Computer as shown in the section "Programming". The configuration by dipswitches can be made also if the device is powered (note: after the configuration the device takes some seconds to provide the right output measure).

# TECHNICAL SPECIFICATIONS (Typical at 25 °C and in nominal conditions)

INPUT			OUTPUT (2 CHANNELS)				POWER SUPPLY		
Input type	Min	Мах	Min.Span	Output type	Min	Max	Min Span	Power supply voltage	18 30 Vdc
TC (CJC int./ext.)	-200°C	1200°C	100°C	Current Voltage	0 mA 0 V	20 mA 10 V	4 mA 1 V	Reverse polarity protection	60 Vdc max
K S R	-200°C 0°C 0°C	1300°C 1750°C 1750°C	100°C 400°C 400°C	Output calibratio				Current output 55 mA max. Voltage output 25 mA max.	
B	0°C -200°C	1850°C 1000°C	400°C 100°C	Current     ± 7 uA       Voltage     ± 5 mV       Burn-out values     22 mA or 10.6 V		ISOLATION			
T N	-200°C -200°C	400°C 1300°C	100°C 100°C			Among all ways	1500 Vac, 50 Hz, 1 min		
Voltage mV	-100 mV		5 mV	Min. output value 0 mA or -0.6 V TEMPERATURE AND			TEMPERATURE AND HUM Operative temperature	<b>IDITY</b> -20°C +60°C	
mV mV	-100 mV	+200 mV +800 mV		Output load Resistance - RloadCurrent output< 500 $\Omega$		Storage temperature -40°C +85°C Humidity (not condensed) 0 90 %			
Input calibration (1) mV, TC the higher of $\pm$ 0.1% f.s. and $\pm$ 12 uV			Voltage output> 10 K $\Omega$ Short circuit current26 mA max.			HOUSING Material Self-extinguishing plastic			
Linearity (1)           TC         ± 0.2 % f.s.           mV         ± 0.1 % f.s.			Response time (10÷ 90%) about 500 ms			00 ms	Mounting DIN rail in compliance with EN-50022 and EN-50035		
Input impedance TC, mV >= 10 MΩ					Weight about 90	•			
Line resistance influence (1) TC, mV <=0.8 uV/Ohm							EMC ( for industrial enviro	EN 61000-6-2	
Thermal drift (1) Full scale ± 0.01% / °C						Emission	EN 61000-6-4		
CJC CJC comp.	$\pm 0.01\%$ $\pm 0.01\%$ $\pm 0.5°C$								
(1)referred to the input Span (difference between max. and min.)									

### **CONFIGURATION BY DIP-SWITCHES**



TAB.2


setting

# **PROGRAMMING**

- 1) Open the suitable door on the side of the device
- 2) Set the input type by the dip-switch SW1 [1..4] (see TAB.1)
- 3) Set the minimum input scale value (Zero) by the dip-switch SW1 [5..8] (see TAB.3)
- 4) Set the maximum input value (Full scale) by the dip-switch SW2 [1..6] (see TAB.3)
- 5) Set the output type by the dip-switch SW2 [7..8] (see TAB.2)

SW2

180



°C

75

80

85

90

95

100

110

120

130

140

150

160

170

190

200

### NOTE:

Full Scale

°C

0

5

10

15

20

25

30

35

50

70

Default

SW2

40

45

55

60

65

TAB.3 - Input scale setting

Zero

8 °C

Default

-200

-100

-80

-60

-50

-40

-30

-20

-10

0

10

20

50

100

150

SW1

- It is also possible to set the dip-switches using the wizard of the configuration software following the procedure described in the section "Configuration by PC" until the step 6 and clicking on "Switch".

SW2

°C

225

250

255

275

300

325

350

375

400

425

450

475

500

550

600

650

SW2

°C

700

750

800

850

900

950

1000

1100

1200

1300

1400

1500

1600

1750

1800

1850

### **DIP-SWITCH CONFIGURATION TABLES**

IA	р.	1
Inn	ut	t١

Input type	setting	Outp	out setting		
9 1000 2	EPROM * 90 mV 200 mV	SW1 1 2 3 4	Tc K Tc R Tc S	SW2 7 8	0-20 m/ 4-20 m/ 0-10 V
	300 mV   		Tc T Tc B Tc E Tc N		0-5 V
	C J				

### NOTES:

- \* If the dip-switches SW1 [1..4] are all set in the position 0 ("EPROM"), the device will follow the configuration programmed by PC ( input type and range, output type and range and options)
- \* For all the "Tc" type selected by dip-switches, the cold junction compensation is internal.
- \* If the dip-switches SW1 [5..8] are all set in the position 0 ("Default"), the device will follow the input scale programmed by PC for the input type selected by the dip-switches SW1 [1..4]
- Eventual wrong dip-switches settings will be signalled by the blinking of the led "PWR".


### **CONFIGURATION BY PC**

By software DATESOFT it is possible to:

- set the default programming of the device;
- program the options not available with the dip-switch; (burn-out level, CJC offset, etc...);
- read, in real time, the input and output measures;
- follow the dip-switches configuration wizard.

To configure the device follow the next steps:

- 1) Power-on the device.
- 2) Open the protection plastic label on the front of the device.
- 3) Connect the interface PRODAT to the PC (COM port)
- and to the device (PGRM connector). 4) Open DATESOFT.
- 5) Select the COM port in use.
- 6) Click on "Open COM".
- Click on "Program".
- 8) Set the programming data.
- 9) Click on "Write" to send the programming data to the device.



Warning: during these operations the device must always be powered and the TX/RX cable always connected. For information about DATESOFT refer to the software's user guide.

# **INSTALLATION INSTRUCTIONS**

The device is suitable for fitting to DIN rails in the vertical position. For optimum operation and long life follow these instructions:

# When the devices are installed side by side it may be necessary to separate them by at least 5 mm in the following cases:

- If panel temperature exceeds 45°C.

- Use of high power supply value ( > 27 Vdc ).
- Use of output current.

Make sure that sufficient air flow is provided for the device avoiding to place raceways or other objects which could obstruct the ventilation slits. Moreover it is suggested to avoid that devices are mounted above appliances generating heat; their ideal place should be in the lower part of the panel.


Install the device in a place without vibrations.

Moreover it is suggested to avoid routing conductors near power signal cables (motors, induction ovens, inverters etc...) and to use shielded cable for connecting signals.






# **CONNECTIONS**



# Note: terminals G, H, E and F not connected (NC)

**POWER SUPPLY** 



# LIGHT SIGNALLING

LED	COLOUR	STATE	DESCRIPTION
PWR	GREEN	ON	Device powered
		OFF	Device not powered
		BLINKING	Wrong dip-switches setting

# HOM TO ORDER The device is provided as requested on the Customer's order. Refer to the section "Programming" to determine the input and output ranges. In case of the configuration is not specified, the parameters must be set by the user. ORDER CODE EXAMPLE: DAT 4631A / Tc K / 0÷1200 °C / 4÷20 mA / CJC Int. input type input range Output range Output range Options

### **DIMENSIONS (mm)**