

GENERAL DESCRIPTION

The DAT 3016 device is able to acquire up to 4 analog input signals. Data values are transmitted with MODBUS RTU/ASCII protocol on the RS-485 network (RS-232 interface is available).

It is possible to connect Thermocouples or up to +/- 1V voltage signals. The Cold Junction compensation for thermocouples is performed internally.

By means of a 16 bit converter, the device guarantee a high accuracy and a stable measure versus time and temperature.

To ensure the plant safety, two Watch-Dog timer alarms are provided.

The 2000 Vac isolation between input, power supply and serial line removes eventual ground-loop effects, allowing the use of the device even in the heavy environmental conditions

The DAT 3016 is in compliance with the Directive 2004/108/EC on the electromagnetic compatibility.

The device is housed in a rough self-extinguishing plastic container which, thanks to its thin profile of 17.5mm only, allows a high density mounting on EN-50022 standard DIN rail.

COMMUNICATION PROTOCOLS

The DAT3016 is designed to work with the MODBUS RTU/ASCII protocol: standard protocol in field-bus; allows to directly interface DAT3000 series devices to the larger part of PLCs and SCADA applications available on the market. For the protocol instructions, see the relative User Guide.

USER INSTRUCTIONS

Before to install the device, please read the "Installation Instruction" section.

If the module configuration is unknown, it can be hardly to establish a communication with them; connecting the INIT terminal to the GND terminal (ground), at the next power-up the device will be auto-configured in the default settings (see Operating User Guide).

Connect power supply, serial bus and analog inputs as shown in the "Wiring" section.

The "PWR" LED state depending to the working condition of the device: see the "Light Signalling" section to verify the device working state.

To perform configuration and calibration operations, read the instructions in the Operating User Guide.

To simplify handling or replacing of the device, it is possible to remove the wired terminals even with the device powered.

TECHNICAL SPECIFICATIONS (Typical @ 25 °C and in the nominal conditions)

Input type	Min	Max	Input Impedance		Power Supply	
Voltage 25 mV	-25 mV	+25 mV	mV, Tc	> 1 MΩ (2)	Supply Voltage Current consumption Polarity inversion protection	10 30 Vdc 30 mA @ 24 Vdc 60 Vdc max
100 mV 250 mV 1000 mV	-100 mV -250 mV -1000mV	+100 mV +250 mV +1000mV	Thermal drift Full Scale	± 0.005 % / °C (1)	Isolation	2000 Vac 50 Hz, 1 min.
Thermocouple J K	-210 °C -210 °C	+1200 °C +1372 °C		± 0.02 %/ °C	Supply – Input Supply – RS485	2000 Vac 50 Hz, 1 min. 2000 Vac 50 Hz, 1 min. 2000 Vac 50 Hz, 1 min.
R S B	-50 °C -50 °C +400 °C	+1767 °C +1767 °C +1825 °C	Lead wire resistand mV, Tc	ce influence < 0.8 uV/Ohm (1)	Temperature & Humidity Operating temperature Storage temperature	-10°C +60°C -40°C +85°C
E T N	-210 °C -210 °C -210 °C	+1000 °C +400 °C +1300 °C	Sample time	0.5 ÷ 1 sec.	Humidity (non condensing) Housing	0 90 %
Input Calibration > ± 0,05% or 5 uV (1)			Data Transmission Baud Rate Max distance	38.4 Kbps 1.2 Km	Material Mounting Weight	Self-extinguishing plastic EN-50022 DIN rail ~ 150 g.
	± 0.1% f.s. (1) ± 0.2% f.s. (1)		Warm-up time	3 min.	EMC (for industrial enviro Immunity Emission	nments) EN 61000-6-2 EN 61000-6-4
Cold Junction Compensation ± 0.5 °C						
NOTE						

NOTE

(1) refered to input Span (difference between max. and min. values)

(2) there is a pull-up resistor $(10M\Omega)$ connected to +1V (break sensor)

INSTALLATION INSTRUCTIONS


The DAT 3016 device is suitable for fitting to DIN rails in the vertical position. For optimum operation and long life follow these instructions:

When the devices are installed side by side it may be necessary to separate them by at least 5 mm in the following case: - If panel temperature exceeds 45°C and at least one of the overload conditions exist.

Make sure that sufficient air flow is provided for the device avoiding to place raceways or other objects which could obstruct the ventilation slits. Moreover it is suggested to avoid that devices are mounted above appliances generating heat; their ideal place should be in the lower part of the panel. Install the device in a place without vibrations.


Moreover it is suggested to avoid routing conductors near power signal cables (motors, induction ovens, inverters etc...) and to use shielded cable for connecting signals.

CABLING



LIGHT SIGNALLING

LED	COLOUR	STATE	DESCRIPTION	
PWR	GREEN	ON	Device powered	
		OFF	Device not powered / Wrong RS-485 cabling.	
		FAST BLINK	Communication in progress (blink frequency depends to baud-rate)	
		1 second BLINK	Watch-Dog Alarm condition	



Datexel s.r.l. reserves its right to modify the characteristics of its products totally or in part without warning at any time.

ANALOG INPUT WIRING

WIRING

Voltage INPUT 0 **INPUT 1 INPUT 2 INPUT 3** C 3 5 Thermocouple INPUT 0 **INPUT 1 INPUT 2 INPUT 3** 6 ${ \mathfrak O }$ A 6 NOTE: input channels are not isolated between them. 2-4-6-8 = Ref. **RS-485 NETWORK WIRING RS-232 NETWORK WIRING** E A ТΧ ⁽⁻⁾ RS-485 D -RX **RS-232** network В **(**F) RX 🗸 4 тχ D + GND C C GND GND **INIT WIRING** POWER SUPPLY WIRING INIT 6 \mathbf{O} 10÷30 Vdc ON: short-circuit to GND ©_{GND} Œ **ISOLATION STRUCTURE** ANALOG **RS485** (RS232) INPUTS

ED.05.06 REV.07